

ORIGINAL

CANADA
PROVINCE OF QUEBEC
CITY OF COTE SAINT-LUC

BY-LAW NO. 1040

BY-LAW AMENDING ARTICLES 2-5 AND 2-8
OF BY-LAW NO. 626, CONCERNING FIRE
PREVENTION.

At the Regular Monthly Meeting of the Municipal Council of the City of Côte Saint-Luc, held at the City Hall, 5490 Westminster Avenue, on Monday, April 1st, 1968, and at which were present:

His Worship Mayor Samuel Moskovitch, Q.C.,
Presiding;

Alderman S. Bierbrier, Notary

Alderman W. E. Kesler

Alderman E. J. Kirwan

Alderman B. Lang, Eng.

Alderman N. Shuster

Alderman I. Singerman

Also present:-

Mr. C. I. Shelley, Eng., City Manager

Mr. J. G. Butler, C.A., City Treasurer

Mr. W. Murray, Eng., City Engineer

Mr. Geo.-H. Dureault, Q.C., City Clerk and Lawyer,
acted as Secretary of the Meeting.

PROPOSED BY ALDERMAN B. LANG

SECONDED BY ALDERMAN S. BIERBRIER

AND RESOLVED:-

THAT IT BE ENACTED AND ORDAINED by By-Law No. 1040 of the City Council and it is hereby enacted and ordained, subject to all the approvals required by the Law, as follows:

ARTICLE 1. By-Law Number 626 is hereby amended by deleting paragraph 2 of Article 2-5 of said By-Law and replacing it by the following:


ARTICLE 2-5, Paragraph 2. Every standpipe system, at every storey, shall be provided with a hose station, the hose to be of an approved model with fog nozzle for the control of spread of spray jet to the exclusion of straightnozzle. The inside diameter of the hose shall not be less than one and a half (1½) inches.

ARTICLE 2. By-Law Number 626 is further amended by adding at the end of Article 2-8 of said By-Law, the following paragraph:


ARTICLE 2-8, Paragraph 4. All control valves of standpipe systems and siamese connections shall, at all times, be opened and kept in this position by special metal seals affixed to same by the Fire Director or his representative. Removal of seals and closing of control valves may be permitted, at the request of the owner of a building or the responsible person thereof, in case of urgent repairs to the water supply system and for a predetermined period of time, only by the Fire Director or an authorized member of the Fire Department who, after completion of the works, shall personally proceed with the installation of new seals on the opened control valves.

It is the responsibility of the registered owner of the building to take whatever precautions may be necessary to keep the valves open and the seals intact.

ARTICLE 3. The present By-Law shall come into force according to Law.



MAYOR OF THE CITY OF COTE SAINT-LUC



CITY CLERK

CITY OF COTE SAINT-LUC
BY-LAW NO. 1040

BY-LAW AMENDING ARTICLES 2-5 AND
2-8 OF BY-LAW NUMBER 626 CONCERNING
FIRE PREVENTION.

Adopted on: *April 1st, 1968*

Published on: *April 3rd, 1968*