

ORIGINAL

PROVINCE OF QUEBEC

CITY OF COTE SAINT-LUC

BY - LAW NO . 977

BY-LAW AMENDING ARTICLE 3-13 OF
BY-LAW NUMBER 626; CONCERNING FIRE
PREVENTION IN THE CITY OF COTE
SAINT-LUC.

At an Adjourned Regular Meeting of the Municipal Council
of the City of Côte Saint-Luc, held at the City Hall, 5490
Westminster Avenue, on Wednesday, May 3rd, 1967, and at which
were present:-

His Worship Mayor Samuel Moskovitch, Q.C., presiding;

Alderman S. Bierbrier, Notary

Alderman W. E. Kesler

Alderman E. J. Kirwan

Alderman B. Lang, Eng.

Alderman N. Shuster

Alderman I. Singerman

Also present:-

Mr. W. Murray, Eng., City Engineer

Mr. J. G. Butler, C.A., City Treasurer and Assistant
City Clerk, acted as Secretary of the Meeting.

PROPOSED BY ALDERMAN B. LANG

SECONDED BY ALDERMAN S. BIERBRIER

AND RESOLVED:-

THAT IT BE ENACTED by a By-Law to the City Council,
and it is hereby enacted and ordained, subject to all approvals
required by Law, as follows:

19-987-5

ARTICLE 1. Article 3-13 of By-Law Number 626, concerning Fire Prevention in the City of Côte Saint-Luc, is hereby amended by adding thereto Article 3-13A reading as follows:

"ARTICLE 3-13A. Exhaust ducts attached to hoods placed above a cooking range or a frying apparatus in residential dwellings shall be of the same cross-sectional area as the exhaust opening provided in the metallic hood of the kitchen exhaust fan. The metallic hood, exhaust fan and exhaust opening must show the stamp of approval of the Underwriters' Laboratories of Canada (U.L.C.).


"The ducts shall be made of galvanized steel, having a minimum thickness of 0.0236 inches or 24 gauge. They shall be designed and installed so that the entire duct can be cleaned if it is not equipped with a removable filter at the intake end.


"Exhaust ducts shall discharge directly to the outside air. Where the duct passes through the ceiling and through the roof, it shall be insulated against heat transmission with non-combustible material (insulation), on the outside face of the duct for its entire length.

"The exhaust outlet shall be shielded from the weather and insects.

"Where the space above the kitchen range or other frying apparatus is not the kitchen ceiling, then this space shall be protected with fireproof material in the manner described in Paragraph 1 of Article 4-12-25 of By-Law No. 928, amending By-Law 127".

ARTICLE 2. The present By-Law shall come into force according to Law and shall form part of, to all intents and purposes, of By-Law Number 626 which it amends.


MAYOR OF THE CITY OF COTE SAINT-LUC


ASSISTANT CITY CLERK

BY-LAW NO. 977

CITY OF COTE SAINT-LUC

PROVINCE OF QUEBEC

BY-LAW AMENDING ARTICLE 3-13 OF
BY-LAW NUMBER 626: CONCERNING FIRE
PREVENTION, IN THE CITY OF COTE
SAINT-LUC.

ORIGINAL

Adopted on:

May 3, 1967

Published on:

May 10, 1967